



Training School for Young Researchers

Fire Engineering Research – Key Issues for
the Future

**Design methods – codified, prescriptive or
performance-based**

Paulo Vila Real




universidade de aveiro

COST Action TU0904 Malta, 11-14 April 2012

Scope

- Introduction
- Thermal Actions
- Mechanical Actions
- Thermal Analysis
- Mechanical Analysis
- Design procedures
- Examples using different design procedures: prescriptive and performance-based



universidade de aveiro

Introduction Question

- Prescriptive or performance-based approach?

Introduction

Two type of regulations or standards


- ❑ Each country has its own **regulations for fire safety of buildings** where the requirements for fire resistance are given
- ❑ Standards for checking the **structural fire resistance** of the buildings - in Europe the structural EUROCODES

Introduction

Fire Resistance

□ Classification criteria

R – Load bearing criterion; **E** – Integrity criterion; **I** – Insulation criterion



- Load bearing only: mechanical resistance (criterion R)
- Load bearing and separating: criteria R, E and when requested, I

Introduction -Fire Resistance

Criteria R, E and I - UK Approved document B

Fire resistance

B3.ii The fire resistance of an element of construction is a measure of its ability to withstand the effects of fire in one or more ways, as follows:

- a. resistance to collapse, i.e. the ability to maintain loadbearing capacity (which applies to loadbearing elements only);
- b. resistance to fire penetration, i.e. an ability to maintain the integrity of the element;
- c. resistance to the transfer of excessive heat, i.e. an ability to provide insulation from high temperatures.

R

E

I


Introduction

Fire Resistance – Criteria R, E and I

□ Standard fire curve

Fire resistance is the time since the beginning of the standard fire curve ISO 834 until the moment that the element doesn't fulfill the functions for that it has been designed (Load bearing and/or separating functions)


$$T = 345 \log_{10}(8t + 1) + 20$$



Introduction

Regulations for fire safety of buildings

- Normally the risk factors are:
 - Height of the last occupied storey in the building (**h**) over the reference plane
 - Number of storeys below the reference plane (**n**)
 - Total gross floor area
 - Number of occupants (effective)



Introduction. Example Regulations for fire safety – UK Approved document B

Office of the Deputy Prime Minister
Creating sustainable communities

The Building Regulations 2000

Fire safety

B

APPROVED DOCUMENT

- B1 Means of warning and escape
- B2 Internal fire spread (linings)
- B3 Internal fire spread (structure)
- B4 External fire spread
- B5 Access and facilities for the fire service

2000 edition
incorporating
2000 and 2002
amendments

PERFORMANCE OF MATERIALS AND STRUCTURES

Table A2 Minimum periods of fire resistance

Purpose group of building	Minimum periods (minutes) for elements of structure in a:				
	Basement storey (\$) including floor over		Ground or upper storey		
	Depth (m) of a lowest basement		Height (m) of top floor above ground, in a building or separated part of a building		
	More than 10	Not more than 10	Not more than 5	Not more than 18	Not more than 30
1. Residential (domestic):					
a. Flats and maisonettes	90	60	30*	60**†	90**
b. and c. Dwellinghouses	Not relevant	30*	30*	60@	Not relevant
2. Residential:					
a. Institutional ce	90	60	30*	60	90
b. Other residential	90	60	30*	60	90
3. Office:					
- Not sprinklered	90	60	30*	60	90
- Sprinklered (2)	60	60	30*	30*	60
4. Shop and commercial:					
- Not sprinklered	90	60	60	60	90
- Sprinklered (2)	60	60	30*	60	60
5. Assembly and recreation:					
- Not sprinklered	90	60	60	60	90

Introduction. Example

Regulations for fire safety – UK Approved document B

INTERNAL FIRE SPREAD (STRUCTURE)

B3

The Requirement

This Approved Document deals with the following Requirement from Part B of Schedule 1 to the Building Regulations 2000.

<i>Requirement</i>	<i>Limits on application</i>
<p>Internal fire spread (structure)</p> <p>B3. (1) The building shall be designed and constructed so that, in the event of fire, its stability will be maintained for a reasonable period.</p> <p>(2) A wall common to two or more buildings shall be designed and constructed so that it adequately resists the spread of fire between those buildings. For the purposes of this sub-paragraph a house in a terrace and a semi-detached house are each to be treated as a separate building.</p> <p>(3) To inhibit the spread of fire within the building, it shall be sub-divided with fire-resisting construction to an extent appropriate to the size and intended use of the building.</p> <p>(4) The building shall be designed and constructed so that the unseen spread of fire and smoke within concealed spaces in its structure and fabric is inhibited.</p>	<p>Requirement B3(3) does not apply to material alterations to any prison provided under Section 33 of the Prisons Act 1952.</p>

Introduction. Example

Portuguese regulation for fire safety of buildings

□ Required fire resistance

- The load-bearing or/and separating function should be maintained during the complete duration of the fire including the decay phase (**this means that natural fires can be used**), or **alternatively** during the required time of standard fire exposure given in the table below:

Standard fire resistance of structural members in buildings


Classification according to the occupancy	Risk categories				Function of the structural member
	1.º	2.º	3.º	4.º	
I, III, IV, V, VI, VII, VIII, IX, X	R30 REI30	R60 REI60	R90 REI90	R120 REI120	Only load bearing Load bearing and separating
II, XI and XII	R60 REI60	R90 REI90	R120 REI120	R180 REI180	Only load bearing Load bearing and separating

Type I «Dwelling»; **Type II «Car parks»;** **Type III «Administrative»;** **Type IV «Schools»;** **Type V «Hospitals»;**
Type VI «Theatres/cinemas and public meetings»; **Type VII «Hotels and restaurants»;**
Type VIII «Shopping and transport centres»; **Type IX «Sports and leisure»;**
Type X «Museums and art galleries»; **Type XI «Libraries and archives»;**
Type XII «Industrial, workshops and storage»

Introduction

Prescriptive or performance-based

- The load-bearing function is ensured when collapse is prevented during the complete duration of the fire including the decay phase or alternatively during the required period of time under standard fire exposure.



Introduction

Codes for fire design in Europe: Structural Eurocodes

Eurocodes

EN 1990	Eurocode:	Basis of Structural Design
EN 1991	Eurocode 1:	Actions on structures
EN 1992	Eurocode 2:	Design of concrete structures
EN 1993	Eurocode 3:	Design of steel structures
EN 1994	Eurocode 4:	Design of composite steel and concrete structures
EN 1995	Eurocode 5:	Design of timber structures
EN 1996	Eurocode 6:	Design of masonry structures
EN 1997	Eurocode 7:	Geotechnical design
EN 1998	Eurocode 8:	Design of structures for earthquake resistance
EN 1999	Eurocode 9:	Design of aluminium structures

Fire design


Parts 1-2 Except EN 1990, EN 1997 and EN 1998, all the Eurocodes have
Part 1-2 for fire design

Fire Design of Structures


Four steps

1. Definition of the thermal loading - EC1
2. Definition of the mechanical loading - EC0 +EC1
3. Calculation of temperature evolution within the structural members – **All the Eurocodes**
4. Calculation of the mechanical behaviour of the structure exposed to fire – **All the Eurocodes**

Eurocode 1: Actions on Structures



Eurocode 1: Actions on Structures




Thermal actions

Heat transfer at surface of building elements

$$\dot{h}_{net,d} = \dot{h}_{net,c} + \dot{h}_{net,r}$$

Total net heat flux



Thermal actions

Heat transfer at surface of building elements

$$\dot{h}_{net,d} = \dot{h}_{net,c} + \dot{h}_{net,r}$$

Total net heat flux

$$\dot{h}_{net,c} = \alpha_c (\theta_g - \theta_m)$$


Convective heat flux

$$\dot{h}_{net,r} = \Phi \cdot \varepsilon_f \cdot \varepsilon_m \cdot \sigma \cdot [(\theta_r + 273)^4 - (\theta_m + 273)^4]$$

Radiative heat flux


$$\theta_g \approx \theta_r$$

Temperature of the fire compartment



Nominal
fire


or



Natural
fire

Actions on Structures Exposed to Fire

EN 1991-1-2 - Prescriptive rules or performance-based approach



Actions on Structures Exposed to Fire

EN 1991-1-2 - Prescriptive rules or performance-based approach

Nominal temperature-time curves

Standard temperature-time curve

External fire curve

Hydrocarbon curve

Natural fire models

Simplified fire models

Compartment fires - Parametric fire

Localised fires – Heskestad or Hasemi







Advanced fire models

Two-Zones or One-Zone fire or a combination

CFD – Computational Fluid Dynamics


Actions on Structures Exposed to Fire

EN 1991-1-2 - Prescriptive rules or performance-based approach

From DIFISEK+	<p><b style="color: red;">*) Nominal temperature-time curve Standard temperature-, External fire - & Hydrocarbon fire curve</p>	<p>No data needed</p>		
	<p><b style="color: red;">*) Simplified Fire Models</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; border-right: 1px solid black; padding: 5px;"> <p><u>Localised Fire</u></p> <ul style="list-style-type: none"> - HESKESTADT - HASEMI <p style="text-align: center;">$\theta(x, y, z, t)$</p>  </td> <td style="width: 50%; padding: 5px;"> <p><u>Fully Engulfed Compartment</u></p> <ul style="list-style-type: none"> - Parametric Fire <p style="text-align: center;">$\theta(t)$ uniform in the compartment</p>  </td> </tr> </table>	<p><u>Localised Fire</u></p> <ul style="list-style-type: none"> - HESKESTADT - HASEMI <p style="text-align: center;">$\theta(x, y, z, t)$</p> 	<p><u>Fully Engulfed Compartment</u></p> <ul style="list-style-type: none"> - Parametric Fire <p style="text-align: center;">$\theta(t)$ uniform in the compartment</p> 	<p>Rate of heat release Fire surface Boundary properties Opening area Ceiling height</p>
<p><u>Localised Fire</u></p> <ul style="list-style-type: none"> - HESKESTADT - HASEMI <p style="text-align: center;">$\theta(x, y, z, t)$</p> 	<p><u>Fully Engulfed Compartment</u></p> <ul style="list-style-type: none"> - Parametric Fire <p style="text-align: center;">$\theta(t)$ uniform in the compartment</p> 			
	<p><b style="color: red;">*) Advanced Fire Models</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; border-right: 1px solid black; padding: 5px;"> <ul style="list-style-type: none"> - Two-Zone Model - Combined Two-Zones and One-Zone fire </td> <td style="width: 50%; padding: 5px;"> <ul style="list-style-type: none"> - One-Zone Model </td> </tr> </table> <p style="text-align: center;">- CFD</p>	<ul style="list-style-type: none"> - Two-Zone Model - Combined Two-Zones and One-Zone fire 	<ul style="list-style-type: none"> - One-Zone Model 	<p style="font-size: 2em;">+</p> <p>Exact geometry</p>
<ul style="list-style-type: none"> - Two-Zone Model - Combined Two-Zones and One-Zone fire 	<ul style="list-style-type: none"> - One-Zone Model 			

Simplified fire models

Nominal Temperature-Time Curve



EC3 and EC9 do not use this external fire curve. A special Annex B on both Eurocodes gives a method for evaluating the heat transfer to external steelwork

List of Physical Parameters needed for Natural Fire Models

Boundary properties


Ceiling height

Opening Area


Fire area

Rate of heat release

Fire load density



Characteristics of the Fire Compartment Natural Fire Model



Characteristics of the Fire Load from EN 1991-1-2 Natural Fire Model

Occupancy	Fire Growth Rate	RHR _f [kW/m ²]	Fire Load q _{f,k} 80% fractile [MJ/m ²]
Dwelling	Medium	250	948
Hospital (room)	Medium	250	280
Hotel (room)	Medium	250	377
Library	Fast	500	1824
Office	Medium	250	511
School	Medium	250	347
Shopping Centre	Fast	250	730
Theatre (movie/cinema)	Fast	500	365
Transport (public space)	Slow	250	122

Design value of the fire load density Natural Fire Model

$$q_{f,d} = q_{f,k} \cdot m \cdot \delta_{q1} \cdot \delta_{q2} \cdot \delta_n \quad [\text{MJ/m}^2]$$

m – Combustion factor. Its value is between 0 and 1. For mainly cellulosic materials a value of 0.8 may be taken. Conservatively a value of 1 can be used

δ_{q1} – factor taking into account the fire activation risk due to the size of the compartment

δ_{q2} – factor taking into account the fire activation risk due to the type of occupancy

δ_n – factor taking into account the different fire fighting measures

$$\delta_n = \prod_{i=1}^{10} \delta_{ni} = \delta_{n1} \cdot \delta_{n2} \cdot \dots \cdot \delta_{n9} \cdot \delta_{n10}$$

Characteristics of the Fire Load from EN 1991-1-2 Natural Fire Model


Compartment floor area A_f [m ²]	Danger of Fire Activation δ_{q1}	Danger of Fire Activation δ_{q2}	Examples of Occupancies
25	1,10	0,78	Art gallery, museum, swimming pool
250	1,50	1,00	Residence, hotel, office
2500	1,90	1,22	Manufactory for machinery & engines
5000	2,00	1,44	Chemical laboratory, Painting workshop
			Manufactory of fireworks

$$q_{f,d} = \delta_{q1} \cdot \delta_{q2} \cdot \prod \delta_{ni} \cdot m \cdot q_{f,k}$$

From DIFISEK+


Automatic Fire Suppression		Automatic Fire Detection			Manual Fire Suppression				
Automatic Water Extinguishing System δ_{n1}	Independent Water Supplies 0 1 2 δ_{n2}	Automatic fire Detection & Alarm by Heat δ_{n3}	Automatic Alarm Transmission to Fire Brigade δ_{n4}	Automatic Alarm Transmission to Fire Brigade δ_{n5}	Work Fire Brigade δ_{n6}	Off Site Fire Brigade δ_{n7}	Safe Access Routes δ_{n8}	Fire Fighting Devices δ_{n9}	Smoke Exhaust System δ_{n10}
0,61	1,0 0,87 0,7	0,87 or 0,73	0,87	0,87	0,61 or 0,78		0,9 or 1 / 1,5	1,0 / 1,5	1,0 / 1,5

Rate of Heat Release Curve from EN 1991-1-2 Natural Fire Model




From DIFISEK+


Rate of Heat Release of a class 3 car. Experimental evaluation Natural Fire Model



Car of class 3



An idealized Rate of Heat Release Curve for a car burning Natural Fire Model



Class 3	
Time (min)	Rate of heat release (MW)
0	0
4	1.4
16	1.4
24	5.5
25	8.3
27	4.5
38	1
70	0


From ECSC Project: Demonstration of real fire tests in car parks and high buildings.

Localised Fire: HESKESTAD Method Natural Fire Model

Annex C of EN 1991-1-2:

- Flame is not impacting the ceiling of a compartment ($L_f < H$)
- Fires in open air

$$\Theta_{(z)} = 20 + 0,25 (0,8 Q_c)^{2/3} (z-z_0)^{-5/3} \leq 900^\circ\text{C}$$




The flame length L_f of a localised fire is given by :

$$L_f = -1,02 D + 0,0148 Q^{2/5}$$

Localised Fire:HASEMI Method Natural Fire Model


Annex C of EN 1991-1-2:

- Flame is impacting the ceiling ($L_f > H$)



Localised fires in a car park

Five fire scenarios



Height: $H = 2.7 \text{ m}$


Diameter of flame: $D = 3.9 \text{ m}$

Steel Beams: IPE 500

Localised fire

Rate of heat release of four burning cars

Curve of the rate of heat release of each car. A delay of 12 minutes between each burning car.




From ECSC Project: Demonstration of real fire tests in car parks and high buildings.

Two Localised fire models

Flame length


if $L_r \geq H \Rightarrow$ Hasemi method has to be used

if $L_r < H \Rightarrow$ Heskestad method has to be used




Program Elefir-EN



Heskestad Method




Hasemi Method



Hasemi method Horizontal distances



Program Elefir-EN




$$r_i = \sqrt{d_1^2 + d_2^2}$$


Temperature development

Gas and steel temperature


Scenario 1: unprotected steel
 $(\theta_{a,max} = 710.9 \text{ }^\circ\text{C})$




Scenario 1: protected steel
 $(\theta_{a,max} = 527 \text{ }^\circ\text{C})$




Scenario 2
 $(\theta_{a,max} = 466.7 \text{ }^\circ\text{C})$




Scenario 3 ($\theta_{a,max} = 466.7 \text{ }^\circ\text{C}$)



Scenario 4 ($\theta_{a,max} = 510.9 \text{ }^\circ\text{C}$)



Scenario 3 ($\theta_{a,max} = 528.5 \text{ }^\circ\text{C}$)



Parametric fire. Needed parameters Natural Fire Model

Fire load density -	$q_{f,d}$	} Temperature $\theta = \theta(t)$
Opening factor -	$O = A_v \sqrt{h} / A_t$	
Wall factor -	$b = \sqrt{\rho c \lambda}$	


A_v - area of vertical openings; A_t - total area of enclosure

Limitations :

- $A_{\text{floor}} \leq 500 \text{ m}^2$
- No horizontal openings
- $H \leq 4 \text{ m}$
- Wall factor from 1000 to 2200
- Fire load density, $q_{t,d}$ from 50 to 1000 MJ/m²

Parametric Fire Natural Fire Model

Annex A of EN 1991-1-2



— Ventilation controlled fires — Fuel controlled fires

Parametric fire curves function of - O

For a given $q_{f,d}$, b , A_t and A_f

Parametric Fire - Influence of the Actives Fire Safety Measures Natural Fire Model

No Fire Active Measures					1567 = 511x0,8x1,14x1x1x1x1x1x1,5x1,5x1,5
Off Site Fire Brigade					815 = 511x0,8x1,14x1x1x1x1x1x0,78x1x1,5x1,5
Safe access routes					397 = 511x0,8x1,14x1x1x1x1x0,73x1x1x0,78x1x1x1,5
Automatic Fire Detection & Alarm by Smoke					210 = 511x0,8x1,14x1x1x0,61x1x1x0,73x0,87x1x0,78x1x1,5x1,5
Fire fighting devices					
Automatic water extinguishing system - Sprinklers					
Automatic alarm transmission to fire brigade					


Office

$$A_f = 45,0 \text{ m}^2$$

$$O = 0,08 \text{ m}^{1/2}$$

$$q_{f,k} = 511 \text{ MJ/m}^2$$

$$m = 0,8$$




Fire Design of Steel Structures


Four steps

1. Definition of the thermal loading - **EC1**
2. Definition of the mechanical loading - **EC0 +EC1**
3. Calculation of temperature evolution within the structural members - **EC3**
4. Calculation of the mechanical behaviour of the structure exposed to fire - **EC3**

Actions on Structures



Actions on Structures



Combination Rules for Mechanical Actions EN 1990: Basis of Structural Design

- At room temperature (**20 °C**)

$$\sum_{j \geq 1} \gamma_{G,j} G_{k,j} + \gamma_{Q,1} \cdot Q_{k,1} + \sum_{i > 1} \gamma_{Q,i} \psi_{0,i} \cdot Q_{k,i}$$

- In fire situation

1. Fire is an accidental action.
2. The simultaneous occurrence of other independent accidental actions need not be considered

$$\sum_{j \geq 1} G_{k,j} + (\psi_{1,1} \text{ ou } \psi_{2,1}) \cdot Q_{k,1} + \sum_{i > 1} \psi_{2,i} \cdot Q_{k,i} + A_d$$

$\psi_{1,1} Q_{k,1}$ – Frequent value of the representative value of the variable action Q_1

$\psi_{2,1} Q_{k,1}$ – Quasi-permanent value of the representative value of the variable action Q_1

A_d – Indirect thermal action due to fire induced by the restrained thermal expansion
may be neglected for member analysis

Combination Rules for Mechanical Actions EN 1990: Basis of Structural Design

$$\sum_{j \geq 1} G_{k,1} + (\psi_{1,1} \text{ ou } \psi_{2,1}) \cdot Q_{k,1} + \sum_{i > 1} \psi_{2,i} \cdot Q_{k,i} + A_d$$

Action	Ψ_1	Ψ_2
Imposed loads in buildings, category (see EN 1991-1-1)	0.5	0.3
Imposed loads in congregation areas and shopping areas	0.7	0.6
Imposed loads in storage areas	0.9	0.8
vehicle weight ≤ 30 kN	0.7	0.6
30 kN \leq vehicle weight ≤ 160 kN	0.5	0.3
Imposed loads in roofs	0.0	0.0
Snow (Norway, Sweden ...)	0.2	0.0
Wind loads on buildings	0.2	0.0

In some countries the National Annex recommends Ψ_1, Q_1 , so that wind is always considered and so horizontal actions are always taken into account

Fire Design of Steel Structures

Four steps

1. Definition of the thermal loading - EC1
2. Definition of the mechanical loading - EC0 +EC1
3. Calculation of temperature evolution within the structural members - EC3
4. Calculation of the mechanical behaviour of the structure exposed to fire - EC3

Thermal response

Heat conduction equation

$$\frac{\partial}{\partial x} \left(\lambda \frac{\partial \theta}{\partial x} \right) + \frac{\partial}{\partial y} \left(\lambda \frac{\partial \theta}{\partial y} \right) + \dot{Q} = \rho c_p \frac{\partial \theta}{\partial t}$$

Boundary conditions

$$q_c = h_c (\theta - \theta_\infty) \quad \text{convection}$$


$$q_r = \beta \varepsilon (\theta^4 - \theta_a^4) = \underbrace{\beta \varepsilon (\theta^2 + \theta_a^2)}_{h_r} (\theta + \theta_a) (\theta - \theta_a) = h_r (\theta - \theta_a) \quad \text{radiation}$$

Thermal response

Temperature field by Finite Element Method – After 30 min. ISO

$$\frac{\partial}{\partial x} \left(\lambda \frac{\partial \theta}{\partial x} \right) + \frac{\partial}{\partial y} \left(\lambda \frac{\partial \theta}{\partial y} \right) + \dot{Q} = \rho c_p \frac{\partial \theta}{\partial t}$$

Concrete (30x30 cm²)



Note: this equation can be simplified for the case of current steel profiles

Temperature increase of unprotected steel

Simplified equation of EC3

Temperature increase in time step Δt :

$$\Delta\theta_{a,t} = k_{sh} \frac{A_m/V}{c_a \rho_a} \dot{h}_{net,d} \Delta t$$


Heat flux $\dot{h}_{net,d}$ has 2 parts:

Radiation:

$$\dot{h}_{net,r} = 5,67 \times 10^{-8} \Phi \varepsilon_f \varepsilon_m \left((\theta_r + 273)^4 - (\theta_m + 273)^4 \right)$$

Convection:


$$\dot{h}_{net,c} = \alpha_c (\theta_g - \theta_m)$$



Section factor A_m/V

Unprotected steel members

$$\Delta\theta_{a,t} = k_{sh} \frac{A_m/V}{C_a \rho_a} \dot{h}_{net,d} \Delta t$$




Correction factor for the Shadow effect k_{sh}

For I-sections under nominal fire: $k_{sh} = 0.9 [A_m/V]_b/[A_m/V]$


In all other cases: $k_{sh} = [A_m/V]_b/[A_m/V]$

For cross-sections convex shape: $k_{sh} = 1$  

$[A_m/V]_b$ - Section factor as the profile has a hollow encasement fire protection




$$\frac{2(b+h)}{\text{c/s area}}$$



$$\frac{2h+b}{\text{c/s area}}$$

Nomogram for temperature Unprotected steel profiles

Nomogram for unprotected steel members subjected to the ISO 834 fire curve, for different values of $k_{sh} \cdot Am/V$ [m^{-1}]



Structural fire protection

Passive Protection

Insulating Board

Gypsum, Mineral fibre, Vermiculite.
Easy to apply, aesthetically acceptable.
Difficulties with complex details.

Cementitious Sprays


Mineral fibre or vermiculite in cement binder.
Cheap to apply, but messy; clean-up may be expensive.
Poor aesthetics; normally used behind suspended ceilings.

Intumescent Paints


Decorative finish under normal conditions.
Expands on heating to produce insulating layer.
Can be done off-site.

Structural fire protection

Columns:




Beams:



- (a) - Spray or intumescent
- (b) - Board
- (c) - Board

Structural fire protection
Intumescent paint



Structural fire protection
Cementitious Sprays



Structural fire protection Insulating Board




Temperature increase of protected steel

Simplified equation of EC3

- **Some heat stored in protection layer.**
- **Heat stored in protection layer relative to heat stored in steel**

$$\phi = \frac{c_p \rho_p}{c_a \rho_a} d_p \frac{A_p}{V}$$


- **Temperature rise of steel in time increment Δt**



$$\Delta\theta_{a.t} = \frac{\lambda_p / d_p}{c_a \rho_a} \frac{A_p}{V} \left(\frac{1}{1 + \phi/3} \right) (\theta_{g.t} - \theta_{a.t}) \Delta t - (e^{\phi/10} - 1) \Delta\theta_{g.t}$$


Section factor A_p/V Protected steel members

$$\Delta\theta_{a,t} = \frac{\lambda_p / d_p}{c_a \rho_a} \frac{A_p}{V} \left(\frac{1}{1 + \phi/3} \right) (\theta_{g,t} - \theta_{a,t}) \Delta t - (e^{\phi/10} - 1) \Delta\theta_{g,t}$$



Nomogram for temperature Protected steel profiles


Nomogram for unprotected steel members subjected to the ISO 834 fire curve, for different values of $[A_p/M][\lambda_p/d_p]$ [W/Km³]



Fire Design of Steel Structures Four Steps

1. Definition of the thermal loading - **EC1**
2. Definition of the mechanical loading - **EC0 +EC1**
3. Calculation of temperature evolution within the structural members - **EC3**
4. Calculation of the mechanical behaviour of the structure exposed to fire - **EC3**


Degree of simplification of the structure



Analysis of: a) Global structure; b) Parts of the structure; c) Members

Mechanical properties of carbon steel


Stress-strain relationship at elevated temperatures



Mechanical properties of carbon steel


Stress-strain relationship at elevated temperatures

- ◆ Strength/stiffness reduction factors for elastic modulus and yield strength (2% total strain).
- ◆ Elastic modulus at 600°C reduced by about 70%.
- ◆ Yield strength at 600°C reduced by over 50%.




Reduction factors for stress-strain relationship of carbon steel at elevated temperatures

Steel Temperature θ_a	Reduction factors at temperature θ_a relative to the value of f_y or E_a at 20°C		
	Reduction factor (relative to f_y) for effective yield strength $k_{y,\theta} = f_{y,\theta} / f_y$	Reduction factor (relative to f_y) for proportional limit $k_{p,\theta} = f_{p,\theta} / f_y$	Reduction factor (relative to E_a) for the slope of the linear elastic range $k_{E,\theta} = E_{a,\theta} / E_a$
20°C	1,000	1,000	1,000
100°C	1,000	1,000	1,000
200°C	1,000	0,807	0,900
300°C	1,000	0,613	0,800
400°C	1,000	0,420	0,700
500°C	0,780	0,360	0,600
600°C	0,470	0,180	0,310
700°C	0,230	0,075	0,130
800°C	0,110	0,050	0,090
900°C	0,060	0,0375	0,0675
1000°C	0,040	0,0250	0,0450
1100°C	0,020	0,0125	0,0225
1200°C	0,000	0,0000	0,0000



Checking Fire Resistance: Strategies with nominal fires



1. Time:

$$t_{fi,d} > t_{fi,requ}$$


2. Load resistance:

$$R_{fi,d,t} > E_{fi,d}$$

3. Temperature:

$$\theta_d < \theta_{cr,d}$$

Checking Fire Resistance: Strategies with natural fires



1. Load resistance:

$$R_{fi,d,t} > E_{fi,d}$$

collapse is prevented during the complete duration of the fire including the decay phase or during a required period of time.

2. Temperature:


$$\theta_d < \theta_{cr,d}$$

collapse is prevented during the complete duration of the fire including the decay phase or during a required period of time.


Note: With the agreement of authorities, verification in the time domain can be also performed. The required period of time defining the fire resistance must be accepted by the authorities.

Checking Fire Resistance: Strategies with natural fires

The **Load-bearing function** is ensured if collapse is prevented during the complete duration of the fire including the decay phase, or during a required period of time.



Collapse is prevented during the complete duration of the fire including the decay phase.



Collapse is prevented during a required period of time, $t_{fi,requ}^1$

Design procedures

- Tabulated data (EC2, EC4, EC6)**
- Simple calculation models (All the Eurocodes)**
- Advanced calculation models (All the Eurocodes)**

Eurocode 2: Tabulated data

Fire resistance of a RC beam

Table 5.5: Minimum dimensions and axis distances for simply supported beams made with reinforced and prestressed concrete


Standard fire resistance	Minimum dimensions (mm)						
	Possible combinations of a and b_{min} where a is the average axis distance and b_{min} is the width of beam				Web thickness b_w		
					Class WA	Class WB	Class WC
1	2	3	4	5	6	7	8
R 30	$b_{min}=80$ $a=25$	120 20	160 15*	200 15*	80	80	80
a) R 60	$b_{min}=120$ $a=40$	160 35	200 30	300 25	100	80	100
R 90	$b_{min}=150$ $a=55$	200 45	300 40	400 35	110	100	100
b) R 120	$b_{min}=200$ $a=85$	240 60	300 55	500 50	130	120	120
R 180	$b_{min}=240$ $a=80$	300 70	400 65	600 60	150	150	140
R 240	$b_{min}=280$ $a=90$	350 80	500 75	700 70	170	170	160

$a_{sd} = a + 10\text{mm}$ (see note below)


For prestressed beams the increase of axis distance according to 5.2(5) should be noted.

a_{sd} is the axis distance to the side of beam for the corner bars (or tendon or wire) of beams with only one layer of reinforcement. For values of b_{min} greater than that given in Column 4 no increase of a_{sd} is required.

* Normally the cover required by EN 1992-1-1 will control.



a) R 60




b) R 180


Eurocode 4: Tabulated data

Fire resistance of a RC column

Table 4.4: Minimum cross-sectional dimensions, minimum concrete cover of the steel section and minimum axis distance of the reinforcing bars, of composite columns made of totally encased steel sections.

		Standard Fire Resistance					
		R30	R60	R90	R120	R180	R240
1.1	Minimum dimensions h_c and b_c [mm]	150	180	220	300	350	400
1.2	minimum concrete cover of steel section c [mm]	40	50	50	75	75	75
1.3	minimum axis distance of reinforcing bars u_s [mm]	20*	30	30	40	50	50
or							
2.1	Minimum dimensions h_c and b_c [mm]	-	200	250	350	400	-
2.2	minimum concrete cover of steel section c [mm]	-	40	40	50	60	-
2.3	minimum axis distance of reinforcing bars u_s [mm]	-	20*	20*	30	40	-

NOTE: *) These values have to be checked according to 4.4.1.2 of EN 1992-1-1




R 120

Design procedures

- Tabulated data (EC2, EC4, EC6)
- Simple calculation models (All the Eurocodes)
- Advanced calculation models (All the Eurocodes)

Eurocode 4: Simple calculation model

Sagging moment resistance of a composite beam




$$M_{fi,Rd^+} = T (y_F - y_T)$$


Eurocode 2: Simplified calculation model

500°C isotherm method

Damaged concrete, i.e. concrete with temperatures in excess of 500°C, is assumed not to contribute to the load bearing capacity of the member, whilst the residual concrete cross-section retains its initial values of strength and modulus of elasticity.




Eurocode 2: Simplified calculation model 500°C isotherm method – RC beam



Eurocode 2: Simplified calculation model

Sagging moment resistance of a RC beam



Eurocode 3: Fire Resistance: Tension members - 1


- The design resistance of a tension member with uniform temperature θ_a is:

$$N_{fi,\theta,Rd} = k_{y,\theta} A f_y / \gamma_{M,fi}$$

or

$$N_{fi,\theta,Rd} = k_{y,\theta} N_{Rd} [\gamma_{M0} / \gamma_{M,fi}]$$

N_{Rd} = design resistance of the cross-section $N_{pl,Rd}$ for normal temperature design 77



Eurocode 3: Fire Resistance: Compression members with Class 1, 2 or 3 cross-sections - 1

- Design buckling resistance of a compression member with uniform temperature θ_a is

$$N_{b,fi,\theta,Rd} = \chi_{fi} A k_{y,\theta} f_y \frac{1}{\gamma_{M,fi}}$$

With


$$\chi_{fi} = \frac{1}{\phi_{\theta} + \sqrt{\phi_{\theta}^2 - \bar{\lambda}_{\theta}^2}}$$

$$\phi_{\theta} = \frac{1}{2} \left[1 + \alpha \bar{\lambda}_{\theta} + \bar{\lambda}_{\theta}^2 \right]$$

$$\alpha = 0.65 \sqrt{235 / f_y} \quad (\text{Curves a, b, c, d, a}_0)$$

- Non-dimensional slenderness:

$$\bar{\lambda}_{\theta} = \bar{\lambda} \sqrt{k_{y,\theta} / k_{E,\theta}}$$



Eurocode 3: Fire Resistance: Laterally restrained beams with Class 1, 2 or 3 cross-sections with uniform temperature - 1

- The design moment resistance of a Class 1, 2 or Class 3 cross-section with a uniform temperature θ_a is:


$$\rightarrow M_{fi,\theta,Rd} = M_{Rd} k_{y,\theta} \left(\frac{\gamma_{M0}}{\gamma_{M,fi}} \right)$$

$$M_{Rd} = M_{pl,Rd} \text{ – Class 1 or 2 cross-sections}$$

$$M_{Rd} = M_{el,Rd} \text{ – Class 3 cross-sections}$$

Eurocode 3: Fire Resistance: Laterally restrained beams with Class 1, 2 or 3 cross-sections with non-uniform temperature - 2

Adaptation factors to take into account the non-uniform temperature distribution



Moment Resistance:

$$M_{fi,\theta,Rd} = M_{Rd} k_{y,\theta} \left(\frac{\gamma_{M0}}{\gamma_{M,fi}} \right) \frac{1}{K_1 K_2}$$

K_1 is an adaptation factor for non-uniform temperature across the cross-section




$K_1=1,0$ for a beam exposed on all four sides

$K_1=0,7$ for an unprotected beam exposed on three sides

$K_1=0,85$ for a protected beam exposed on three sides ⁸⁰

Eurocode 3: Fire Resistance: Laterally restrained beams with Class 1, 2 or 3 cross-sections with non-uniform temperature - 3

Adaptation factors to take into account the non-uniform temperature distribution



Moment Resistance:


$$M_{fi,\theta,Rd} = M_{Rd} k_{y,\theta} \left(\frac{\gamma_{M0}}{\gamma_{M,fi}} \right) \frac{1}{k_1 k_2}$$

k_2 is an adaptation factor for non-uniform temperature along the beam.

$k_2=0,85$ at the supports of a statically indeterminate beam

$k_2=1.0$ in all other cases

Eurocode 3: Fire Resistance: Laterally unrestrained beams - 1



Lateral-torsional buckling

Eurocode 3: Fire Resistance: Laterally unrestrained beams - 2

- Design lateral torsional buckling resistance moment of a laterally unrestrained beam at the max. temp. in the comp. flange $\theta_{a.com}$ is \rightarrow

$$M_{b.fi.\theta.Rd} = \chi_{LT.fi} W_y k_{y,\theta.com} f_y \frac{1}{\gamma_{M.fi}}$$

- $\chi_{LT.fi}$ the reduction factor for lateral-torsional buckling in the fire design situation.

$$\chi_{LT.fi} = \frac{1}{\phi_{LT,\theta.com} + \sqrt{[\phi_{LT,\theta.com}]^2 - [\bar{\lambda}_{LT,\theta.com}]^2}}$$

$$\bar{\lambda}_{LT,\theta.com} = \bar{\lambda}_{LT} \sqrt{k_{y,\theta.com} / k_{E,\theta.com}}$$

$$\phi_{LT,\theta.com} = \frac{1}{2} \left[1 + \alpha \bar{\lambda}_{LT,\theta.com} + (\bar{\lambda}_{LT,\theta.com})^2 \right]$$

$$\bar{\lambda}_{LT} = \sqrt{\frac{W_y f_y}{M_{cr}}}$$

$$\alpha = 0.65 \sqrt{235 / f_y}$$

~~(Curves a, b, c, d)~~

Eurocode 3: Fire Resistance Shear Resistance

Design shear resistance

$$V_{fi,t,Rd} = k_{y,\theta,web} V_{Rd} \left(\frac{\gamma_{M,0}}{\gamma_{M,fi}} \right)$$

V_{Rd} is the shear resistance of the gross cross-section for normal temperature design, according to EN 1993-1-1.

θ_{web} is the average temperature in the web of the section.

$k_{y,\theta,web}$ is the reduction factor for the yield strength of steel at the steel temperature θ_{web} .

Eurocode 3: Members with Class 1, 2 or 3 cross-sections, subject to combined bending and axial compression - 1

Without lateral-torsional buckling

Class 1 and 2

$$\frac{N_{fi,Ed}}{\chi_{min,fi} A k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_y M_{y,fi,Ed}}{W_{pl,y} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_z M_{z,fi,Ed}}{W_{pl,z} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} \leq 1$$

Class 3

$$\frac{N_{fi,Ed}}{\chi_{min,fi} A k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_y M_{y,fi,Ed}}{W_{el,y} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_z M_{z,fi,Ed}}{W_{el,z} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} \leq 1$$

Eurocode 3: Members with Class 1, 2 or 3 cross-sections, subject to combined bending and axial compression - 2

With lateral-torsional buckling

Class 1 and 2

$$\frac{N_{fi,Ed}}{\chi_{z,fi} A k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_{LT} M_{y,fi,Ed}}{\chi_{LT,fi} W_{pl,y} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_z M_{z,fi,Ed}}{W_{pl,z} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} \leq 1$$

Class 3

$$\frac{N_{fi,Ed}}{\chi_{z,fi} A k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_{LT} M_{y,fi,Ed}}{\chi_{LT,fi} W_{el,y} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} + \frac{k_z M_{z,fi,Ed}}{W_{el,z} k_{y,\theta} \frac{f_y}{\gamma_{M,fi}}} \leq 1$$

Eurocode 3: Fire Resistance


Members with Class 4 cross-sections

Two procedures:

- 1. In the absence of calculation a **critical temperature of 350 °C** should be considered (conservative results).**
- 2. Alternatively use Annex E, considering the **effective area** and the **effective section modulus** determined in accordance with EN 1993-1-3 and EN 1993-1-5, i.e. based on the material properties at 20°C. For the design under fire conditions the design strength of steel should be taken as the 0,2 percent proof strength instead of the strength corresponding to 2% total strain.**


Eurocode 3: Fire Resistance
Design yield strength to be used with simple calculation models

Cross-sectional Class 1, 2 and 3



Eurocode3: Fire Resistance

Concept of critical temperature - 1



The designer should provide the owner with value of the critical temperature, so that the thickness of the fire protection material can be defined in a more economical way.

Note: the concept of critical temperature should only be used if uniform temperature in the cross-section is adopted.

Eurocode 3: Fire Resistance


Concept of critical temperature - 2

The best fit curve to the points of this table can be obtained as:

Steel Temperature θ_a	Reduction factors at temperature θ_a relative to the value of f_y or E_a at 20°C			
	Reduction factor (relative to f_y) for effective yield strength $k_{y,\theta} = f_{y,\theta}/f_y$	Reduction factor (relative to f_y) for proportional limit $k_{p,\theta} = f_{p,\theta}/f_y$	Reduction factor (relative to E_a) for the slope of the linear elastic range $k_{E,\theta} = E_{a,\theta}/E_a$	Reduction factor (relative to f_y) for the design strength of hot rolled and welded thin walled sections (Class 4) $k_{0.2p,\theta} = f_{0.2p,\theta}/f_y$
20 °C	1.000	1.000	1.000	1.000
100 °C	1.000	1.000	1.000	1.000
200 °C	1.000	0.807	0.900	0.890
300 °C	1.000	0.613	0.800	0.780
400 °C	1.000	0.420	0.700	0.650
500 °C	0.780	0.360	0.600	0.530
600 °C	0.470	0.180	0.310	0.300
700 °C	0.230	0.075	0.130	0.130
800 °C	0.110	0.050	0.090	0.070
900 °C	0.060	0.0375	0.0675	0.050
1000 °C	0.040	0.0250	0.0450	0.030
1100 °C	0.020	0.0125	0.0225	0.020
1200 °C	0.000	0.0000	0.0000	0.000

NOTE: For intermediate values of the steel temperature, linear interpolation may be used.

$$k_{y,\theta} = \left\{ 0.9674 \left(e^{\frac{\theta_a - 482}{39.19}} + 1 \right) \right\}^{-1/3.833} \leq 1$$



Eurocode 3: Fire Resistance



Concept of critical temperature - 3

$$k_{y,\theta} = \left\{ 0.9674 \left(e^{\frac{\theta_a - 482}{39.19}} + 1 \right) \right\}^{-1/3.833} \leq 1$$

$$\theta_{a,cr} = (k_{y,\theta})^{-1}$$

$$\theta_{a,cr} = 39.19 \ln \left[\frac{1}{0.9674 k_{y,\theta}^{3.833}} - 1 \right] + 482$$

Fire Resistance: Concept of critical temperature for a member in tension -1



Eurocode 3: Fire Resistance

Concept of critical temperature for a member in tension - 2


- Resistance at normal temperature:

$$N_{Rd} = Af_y/\gamma_{M0}$$

- Resistance in fire situation:

$$N_{fi,Rd} = A k_{y,\theta} f_y / \gamma_{M,fi}$$

≤ 1




Eurocode 3: Fire Resistance

Concept of critical temperature for a member in tension - 3


Collapse occurs when:

$$N_{fi,Rd,t} = N_{fi,Ed}$$





$$A k_{y,\theta} f_y / \gamma_{M,fi} = N_{fi,Ed}$$

$$\Rightarrow k_{y,\theta} = N_{fi,Ed} / (A f_y / \gamma_{M,fi})$$



$$\theta_{a,cr}$$



Eurocode 3: Fire Resistance


Concept of critical temperature for a member in tension - 4

By interpolation


Steel Temperature θ_a	Reduction factors at temperature θ_a relative to the value of f_y or E_a at 20°C			
	Reduction factor (relative to f_y) for effective yield strength $k_{y,\theta} = f_{y,\theta} / f_y$	Reduction factor (relative to f_y) for proportional limit $k_{p,\theta} = f_{p,\theta} / f_y$	Reduction factor (relative to E_a) for the slope of the linear elastic range $k_{E,\theta} = E_{a,\theta} / E_a$	Reduction factor (relative to f_y) for the design strength of hot rolled and welded thin walled sections (Class 4) $k_{0.2p,\theta} = f_{0.2p,\theta} / f_y$
20 °C	1.000	1.000	1.000	1.000
100 °C	1.000	1.000	1.000	1.000
200 °C	1.000	0.807	0.900	0.890
300 °C	1.000	0.613	0.800	0.780
400 °C	1.000	0.420	0.700	0.650
500 °C	0.970	0.360	0.600	0.530
600 °C	0.470	0.180	0.310	0.300
700 °C	0.230	0.075	0.130	0.130
800 °C	0.110	0.050	0.090	0.070
900 °C	0.060	0.0375	0.0675	0.050
1000 °C	0.040	0.0250	0.0450	0.030
1100 °C	0.020	0.0125	0.0225	0.020
1200 °C	0.000	0.0000	0.0000	0.000

NOTE: For intermediate values of the steel temperature, linear interpolation may be used.

$$k_{y,\theta} = N_{fi,Ed} / (A f_y / \gamma_{M,fi})$$



$$\theta_{a,cr} = 39.19 \ln \left[\frac{1}{0,9674 k_{y,\theta}^{3,833}} - 1 \right] + 482$$



Eurocode 3: Fire Resistance


Concept of critical temperature for a member in tension - 5

$$\theta_{a,cr} = 39.19 \ln \left[\frac{1}{0,9674 k_{y,\theta}^{3,833}} - 1 \right] + 482$$

$$k_{y,\theta} = N_{fi,Ed} / (Af_y / \gamma_{M,fi})$$

Eurocode 3

$$\theta_{a,cr} = 39.19 \ln \left[\frac{1}{0,9674 \mu_0^{3,833}} - 1 \right] + 482$$





$$\mu_0 = \frac{E_{fi,d}}{R_{fi,d,0}} = k_{y,\theta} \quad \text{For the case of tension}$$





$$\mu_0 = \frac{E_{fi,d}}{R_{fi,d,0}} = \frac{N_{fi,Ed}}{Af_y / \gamma_{M,fi}}$$

Checking Fire Resistance in the temperature domain: Strategy for nominal fires.



$$\theta_d \leq \theta_{crit} \quad !$$


Checking Fire Resistance in the temperature domain: Strategy for natural fires



$$\theta_{m\acute{a}x} \leq \theta_{crit} !$$

* - or using active fire fighting measures

Checking Fire Resistance in the time domain: Strategy for natural fires – if accepted by the authorities




$$t_{requ} \leq t_{fi,d} \quad !$$

* - or using active fire fighting measures

Design procedures


- Tabulated data (EC2, EC4, EC6)
- Simple calculation models (All the Eurocodes)
- Advanced calculation models (All the Eurocodes)

Advanced calculation models



Temperature field in a profile

Truss without the possibility of expanding longitudinally subjected (collapse time 66.1 min)



Diamond 2007 for SAFIR

FILE: PavFCPv1
 NODES: 621
 BEAMS: 326
 TRUSSES: 0
 SHELLS: 0
 SOILS: 0

IMPOSED DOF PLOT
 POINT LOADS PLOT
 DISPLACEMENT PLOT (x 10)

TIME: 20 sec

Examples using different methodologies. Fire resistance of steel structures

- ❑ Using tables from the suppliers of the fire protection material


Prescriptive approach

- ❑ Comparison between simplified calculation methods and advanced calculation models – **Prescriptive / Performance-based approach**

- ❑ Cases where it is not possible to use simplified calculation method
Performance-based approach

Single storey hall – R60

Steel grade S355



Load combinations

G – Dead load

Q – Live load in the roof

W - Wind


Load combination 1: $G + \psi_{1,Q}Q + \psi_{2,W}W = G + 0.0Q + 0.0W = G$

Load combination 2: $G + \psi_{1,W}W + \psi_{2,Q}Q = G + 0.2W + 0.0Q = G + 0.2W$

Critical temperature for load combination 1

Section	N [kN]	M_1 [kNm]	M_2 [kNm]	q [kN/m]	$l_{fi,y}$ [m]	$l_{fi,z}$ [m]
-	-139.4	0	135.9	0	16.300	-
IPE 500	-139.4	0	0	0	-	4.075

Program Elefir-EN



The screenshot shows the Elefir-EN software interface. The main window is titled 'Elefir-EN' and contains a 'Fire design according to EC3' section with a 'Project name' field and several radio button options for element submission (tension, compression, shear, bending, bending and axial force, bending and compression, bending and shear). The 'Bending and Compression' dialog box is open, showing the following settings:

- Profile: IPE
- Cross-section: IPE 500
- Steel: S355
- Buckling: about y - y or z - z axis
- System length: $L_y = 8150$ mm, $L_z = 4075$ mm
- Buckling coefficients: about y - y axis: $l_{y,fi}/L = 2$, about z - z axis: $l_{z,fi}/L = 1$
- Axial force: Design axial compression load: $N_{b,fi,Ed} = 135.9$ kN
- Bending diagrams: About major axis: **Define** (circled in red), About minor axis: **Define**
- Calculation: Critical temperature function of the loads

A secondary dialog box titled 'How to evaluate the critical temperature?' is also visible, with the following options:

- Carbon Steel: Use interpolation on the table 3.1 from EN 1993-1-2 (recommended), Use the expression (4.22) from EN 1993-1-2
- Stainless Steel: Interpolation on the tables of Annex C from EN 1993-1-2 will be used

Critical temperature for load combination 1

Loads


File Help

Select load:

No moments about the major axis
($M_{y,fi,Ed} = 0$)

End moments

Moments due to in-plane lateral loads



Results

View Help

IPE 500 (Class 1)

Buckling resistance of the element
Critical temperature: 656.0 °C (Reduction factor, $k_{y,\theta}$: 0.336)


Resistance of the cross-section
Critical temperature: 746.3 °C (Reduction factor, $k_{y,\theta}$: 0.174)

Critical temperature used in the next calculations: 656.0 °C

Critical time

End moments

File Help



M_1 (> or < 0) = kNm

M_2 (> or < 0) = kNm

Critical temperature for load combination 2

Section	N [kN]	M_1 [kNm]	M_2 [kNm]	q [kN/m]	$l_{fi,y}$ [m]	$l_{fi,z}$ [m]
IPE 500	-135.9	0	170.9	0.69	16.300	-
	-135.9	0	0	0	-	4.075

Bending and Compression

File Tools Help

Profile: IPE Cross-section: IPE 500 Steel: S355

Buckling:

about y - y axis
 about z - z axis
 about y - y or z - z axis

System length:

$L_y = 8150$ mm
 $L_z = 4075$ mm

Buckling coefficients:

about y - y axis: $l_{y,fi}/L = 2$
about z - z axis: $l_{z,fi}/L = 1$

Axial force

Design axial compression load: $N_{b,fi,Ed} = 139.4$ kN

Bending diagrams

About major axis **Change** About minor axis Define

Lateral torsional buckling verification:

Is lateral torsional buckling allowed? Yes No

Length between lateral restraints: 4075 mm

Loading: Define

Calculation:

Critical temperature function of the loads
 Fire resistance time function of the loads
 Buckling resistance function of steel temperature
 Buckling resistance function of time


Main Menu Next

Loads

File Help

Select load:

No moments about the major axis ($M_{y,fi,Ed} = 0$)
 End moments
 Moments due to in-plane lateral loads
 Moments due to in-plane lateral loads and end moments




Back Next

Critical temperature for load combination 2

Moments due to in-plane lateral loads and end moments

File Help



Distributed load
 Concentrated load

$L = 8150$ mm $\Delta M = 170.900$ kNm
 $q_{fi,Ed} = 0.69$ kN/m $M_Q = 5.72894062$ kNm
 $M_1 (> \text{ or } < 0) = 170.9$ kNm $\beta_M = 1.783$
 $M_2 (> \text{ or } < 0) = 0$ kNm $|M_{max}| = 170.900$ kNm

Back

Bending and Compression

File Tools Help

Profile: IPE Cross-section: IPE 500 Steel: S355

Buckling:

about y - y axis
 about z - z axis
 about y - y or z - z axis

System length:

$L_y = 8150$ mm
 $L_z = 4075$ mm

Buckling coefficients:

about y - y axis: $i_{y,fi}/L = 2$
 about z - z axis: $i_{z,fi}/L = 1$

Axial force

Design axial compression load: $N_{b,fi,Ed} = 135.9$ kN

Bending diagrams

About major axis About minor axis

Lateral torsional buckling verification:

Is lateral torsional buckling allowed? Yes No

Length between lateral restraints: mm


Loading:

Calculation:

Critical temperature function of the loads
 Fire resistance time function of the loads
 Buckling resistance function of steel temperature
 Buckling resistance function of time

Main Menu Next

Critical temperature for load combination 2



The screenshot shows a software window titled "Results" with a menu bar containing "File", "View", and "Help". The main content area displays the following information:

IPE 500 (Class 1)

Buckling resistance of the element
Critical temperature: 637.6 °C (Reduction factor, $k_{y,\theta}$: 0.380)

Resistance of the cross-section
Critical temperature: 708.8 °C (Reduction factor, $k_{y,\theta}$: 0.219)


Critical temperature used in the next calculations: 637.6 °C

At the bottom of the window, there are two buttons: "Back" on the left and "Critical time" on the right.

Critical temperature of the column IPE 500

$$\theta_{a,cr} = \min(656 \text{ }^{\circ}\text{C}; 638 \text{ }^{\circ}\text{C}) = 638 \text{ }^{\circ}\text{C}$$

Critical time with ISO 834 Using Elefir-EN



The image displays the Elefir-EN software interface, which is used for fire design according to EC3. The main window shows the following options and input fields:

- Project name:** [Empty text field]
- Element submitted to:**
 - Element submitted to tension
 - Element submitted to compression
 - Element submitted to shear
 - Element submitted to bending
 - Element submitted to bending and axial force (cross-section)
 - Element submitted to bending and compression
 - Element submitted to bending and shear
- Temperature function of time:**
 - Temperature function of time
 - Time function of temperature
- Safety factors:** [Button]

Version: 1.1.23
Software registered.



Type of calculation dialog:

- Temperature of fire compartment
- Temperature of fire compartment and steel
- OK
- Cancel


Time / Temp dialog:

- Profile:**
 - Profile: IPE
 - Cross-section: IPE 500
 - Steel: Carbon steel
- Data:**
 - Steel temperature: 638 °C
- Main Menu
- Next

Critical time with ISO 834 Using Elefir-EN




Critical time with ISO 834 Using Elefir-EN



$t_{fi,d} < t_{requ} = 60 \text{ min} \Rightarrow$ Fire protection is needed for a critical temperature of $\theta_{a,cr} = 638 \text{ °C}$

Critical time with ISO 834 Using Nomogram



$t_{fi,d} < t_{requ} = 60 \text{ min} \Rightarrow$ Fire protection is needed for a critical temperature of $\theta_{a,cr} = 638 \text{ }^\circ\text{C}$

Table 3 continued: Three Sided I-Section Beams: 450°C

60 minutes				Section factor up to m ⁻¹
Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	
25	0.250	175	0.888	
30	0.260	180	0.910	
35	0.267	185	0.933	
40	0.275	190	0.956	
45	0.284	195	0.978	
50	0.292	200	1.000	
55	0.301	205	1.118	
60	0.309	210	1.231	
65	0.318	215	1.347	
70	0.418	220	1.462	
75	0.438	225	1.570	
80	0.450	230	1.683	
85	0.463	235	1.800	
90	0.505	240	1.924	
95	0.528	245	2.040	
100	0.550	250	2.156	
105	0.573	255	2.271	
110	0.595	260	2.386	
115	0.618	265	2.502	
120	0.640	270	2.617	
125	0.663	275	2.733	
130	0.685	280	2.849	
135	0.708	285	2.964	
140	0.730	290	3.080	
145	0.753	295	3.195	
150	0.775	300	3.311	
155	0.795	305	3.426	
160	0.820	310	3.542	
165	0.843	315	3.657	
170	0.865			

Thickness is intumescent only. Beams with a concrete slab

Page 7 of 14 Content



Table 3 of 14

Table 4 continued: Three Sided I-Section Beams: 500°C

60 minutes			
Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm
30	0.230	180	0.7
35	0.234	185	0.8
40	0.250	190	0.8
45	0.266	195	0.8
50	0.283	200	0.8
55	0.299	205	0.8
60	0.315	210	0.8
65	0.332	215	0.8
70	0.348	220	0.8
75	0.364	225	0.8
80	0.381	230	1.0
85	0.397	235	1.1
90	0.413	240	1.2
95	0.430	245	1.3
100	0.454	250	1.4
105	0.476	255	1.5
110	0.497	260	1.6
115	0.519	265	1.7
120	0.540	270	1.8
125	0.562	275	1.9
130	0.583	280	2.0
135	0.605	285	2.1
140	0.626	290	2.2
145	0.648	295	2.3
150	0.669	300	2.4
155	0.691	305	2.5
160	0.712	310	2.6
165	0.734	315	2.7
170	0.755	320	2.8
175	0.777		

Thickness is intumescent only. Beams with

Table 5 continued: Three Sided I-Section Beams: 550°C

60 minutes				80 minutes		120 minutes	
Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm
30	0.228	180	0.721	185	1.000	180	3.144
35	0.233	185	0.743	190	1.134	165	3.242
40	0.245	190	0.765	195	1.267	170	3.341
45	0.257	195	0.788	170	1.401	175	3.439
50	0.270	200	0.808	175	1.535	180	3.537
55	0.282	205	0.830	180	1.668	165	3.635
60	0.294	210	0.852	185	1.802		
65	0.307	215	0.874	190	1.936		
70	0.319	220	0.896	195	2.070		
75	0.331	225	0.917	200	2.203		
80	0.344	230	0.939	205	2.337		
85	0.356	235	0.961	210	2.471		
90	0.368	240	0.983	215	2.604		
95	0.381	245	1.015	220	2.738		
100	0.393	250	1.042	225	2.872		
105	0.405	255	1.068	230	3.006		
110	0.418	260	1.244	235	3.139		
115	0.437	265	1.320	240	3.273		
120	0.459	270	1.397	245	3.407		
125	0.481	275	1.473	250	3.540		
130	0.503	280	1.549	255	3.674		
135	0.525	285	1.626				
140	0.546	290	1.702				
145	0.568	295	1.778				
150	0.590	300	1.854				
155	0.612	305	1.931				
160	0.634	310	2.007				
165	0.655	315	2.083				
170	0.677	320	2.159				
175	0.699						

Thickness is intumescent only. Beams with a concrete slab.

This Company has sheets for the temperatures: 350, 400, 450, 500, 550, 600, 620, 650 and 700°C

Thickness of intumescent painting

... 600°C, 620°C, 650°C, ...

$$\theta_{a,cr} = 638 \text{ }^{\circ}\text{C}$$

Table 7 continued: Three Sided I-Section Beams: 620°C

60 minutes				90 minutes				120 minutes	
Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm	Section factor up to m ⁻¹	Thickness mm
45	0.235	185	0.518	50	0.420	185	1.000	40	0.945
50	0.244	190	0.530	55	0.441	190	1.101	45	1.023
55	0.254	195	0.543	60	0.463	195	1.202	50	1.101
60	0.263	200	0.555	65	0.484	200	1.303	55	1.179
65	0.272	205	0.587	70	0.506	205	1.403	60	1.257
70	0.281	210	0.619	75	0.527	210	1.504	65	1.335
75	0.291	215	0.650	80	0.549	215	1.605	70	1.413
80	0.300	220	0.682	85	0.570	220	1.706	75	1.491
85	0.309	225	0.714	90	0.592	225	1.807	80	1.569
90	0.318	230	0.746	95	0.613	230	1.908	85	1.647
95	0.328	235	0.778	100	0.635	235	2.008	90	1.725
100	0.337	240	0.809	105	0.656	240	2.109	95	1.803
105	0.346	245	0.841	110	0.678	245	2.210	100	1.881
110	0.355	250	0.873	115	0.699	250	2.311	105	1.96
115	0.365	255	0.905	120	0.721	255	2.412	110	2.038
120	0.374	260	0.936	125	0.742	260	2.513	115	2.116
125	0.383	265	0.968	130	0.764	265	2.614	120	2.194
130	0.382	270	1.000	135	0.785	270	2.714	125	2.272
135	0.402	275	1.063	140	0.807	275	2.815	130	2.35
140	0.411	280	1.126	145	0.828	280	2.916	135	2.428
145	0.420	285	1.190	150	0.850	285	3.017	140	2.506
150	0.432	290	1.253	155	0.871	290	3.118	145	2.584

$$\frac{A_m}{V} = 133.1 \approx 135 \text{ m}^{-1}$$


Thickness of intumescent painting

In some Countries default temperatures are suggested if no calculation is made. Normally for columns or other members susceptible of instability phenomena a critical temperature of 500°C is suggested.

If, instead of a critical temperature of 638°C, a critical temperature of 500°C was used, a thickness of 0,605 mm would be obtained.

$$\theta_{cr} = 638^{\circ}\text{C} \Rightarrow e = 0,402 \text{ mm}$$

$$\theta_{cr} = 500^{\circ}\text{C} \Rightarrow e = 0.605 \text{ mm}$$



More than 50%

Examples using different methodologies. Fire resistance of steel structures

- ❑ Using tables from the suppliers of the fire protection material

Prescriptive approach

- ❑ Comparison between simplified calculation methods and advanced calculation models – **Prescriptive / Performance-based approach**


- ❑ Cases where it is not possible to use simplified calculation method
Performance-based approach

BARREIRO RETAIL PARK




Required fire resistance 90 minutes (R90)

Different zones for fire scenarios



S275

Temperature development for different fire scenarios



Temperatures obtained using the program Ozone

Unit B - Jumbo

Combination of actions: $1.0G_k + \psi_{1,1}Q_{k,1} = 1.0G_k + 0.0Q_{k,1} = G_k$

	N_{Ed} (kN)	M_1 (kN.m)	M_2 (kN.m)	l_{fr}/L	L (m)	θ_{cr} (°C)	$t_{fi,d}$ (min)
HEA 260	80	0.00	23	1.0	7.3	672.9	19.25
HEA 240	34	0.00	45	1.0	7.3	593.5	15.23
IPE 360	0.00	76.0	0.0	-	-	682.8	17.92


Without fire protection

	θ_{cr} (°C)	ISO (min)	Natural Fire Simplified Method (min)	Natural Fire Advanced Method (min)
HEA 260	672.9	> 90	> 90	> 90
HEA 240	593.5	80.8	> 90	
IPE 360	682.8	> 90	> 90	

With fire protection
for R60 and a critical
temperature of 500°C

Deformed shape Obtained with Advanced Calculation Methods


Deformed shape of Unit B (Jumbo supermarket) after 117 minutes of exposure to a natural fire



**Software: GiD (for the numerical model mesh);
SAFIR (for the analysis)**

Examples using different methodologies. Fire resistance of steel structures

- ❑ Using tables from the suppliers of the fire protection material
Prescriptive approach
- ❑ Comparison between simplified calculation methods and advanced calculation models – **Prescriptive / Performance-based approach**
- ❑ Cases where it is not possible to use simplified calculation method
Performance-based approach




EXHIBITION CENTRE

Required fire resistance 120 minutes (R120)

Choice of the structural analysis


The main structure is made of non-uniform class 4 elements. There are no simplified methods, for the time being, for such type of elements. Two options were possible:

- Using a **prescriptive approach**, protect the structure for a critical temperature of 350°C;
- Using **performance-based approach** with advanced calculation methods.



Required fire resistance 120 minutes (R120)


Fire scenarios






6 fire scenarios

Fire load density
reduced by 39% due
to the sprinklers

Fire resistance (R120)




Fire scenarios




C1-5 - Software OZone

C6 is a localized fire in Zone C - Elefir-EN

Main Structure



Structural Analysis




Deformed shape at Zone A, for the combination of actions 1, after 120 minutes (x20)

Conclusions

- A performance-based analysis, demonstrated in this study that, protecting the structure for a standard fire resistance of 60 minutes (R60), considering a critical temperature of 500°C, the load-bearing function is ensured during the complete duration of the fire, including the cooling phase.
- The steel structure of the Center for Exhibitions and Fairs in Oeiras consists of class 4 cross section profiles. In a prescriptive approach and without making any calculation, this structure should have been protected for a critical temperature of 350°C and for R120.


Fire resistance of the steel roof of the Shopping Centre Dolce Vita in Braga, Portugal





Scenario 2


Fire in the compartment D2, C1 and C2



It was assumed that the fire would developed in all the 3 parts D2, C1 and C2.

Scenario 2

Fire in the compartment D2, C1 and C2



Maximum area: $A_{f,max} = 7560 \text{ m}^2$

Fire area: $A_{fi} = 7560 \text{ m}^2$

Openings: the openings area was 554.4 m^2 , located at 10.50 m above the floor level, plus an area of 762 m^2 in a glass façade. It was assumed that 10% of the openings would be opened until 400°C , 50% between 400°C and 500°C and 100% for temperatures higher 500°C (stepwise variation).

Compartment height: 12.67 m

Walls: concrete blocks

Ceiling: Sandwich panels with 0.75 mm thickness steel plate and rock wool of 40 mm thickness and 125 kg/m^3 density.

Rate of Heat Release: $\text{RHR}_f = 250 \text{ kW/m}^2$

Fire growth rate: high, $t_\alpha = 150 \text{ s}$


Fire load density: $q_{f,k} = 730 \text{ MJ/m}^2$

Combustion factor: $m = 1.0$

OZONE


Scenario 2

Fire in the compartment D2, C1 and C2




Gas Temperature

Peak: 558 °C
at: 98 min



Zones Interface Elevation



**h = 2.55 m
at: 20.00 min**

Scenario 4


Localise fire at floor level 1 of part C2



I was considered a localise fire at the floor level 1 of part C2.

Scenario 4

Localise fire at floor level 1 of part C2



Fire diameter: $d_{fi} = 10 \text{ m}$

Temperature calculated at different heights

Compartment height: 36 m

Rate of Heat Release: $RHR_f = 250 \text{ kW/m}^2$

Fire growth rate: high, $t_\alpha = 150 \text{ s}$




Fire load density: $q_{f,k} = 730 \text{ MJ/m}^2$

Combustion factor: $m = 1.0$

Localised fire





Scenario 4

Localise fire at floor level 1 of part C2




SAFIR

Commercial profiles



node 15




SAFIR


Commercial profiles

UB356x171x51 (60min)


node 13



UB356x171x51 protected for R30 (60min)





Temperature evolution




**Built-up
section
profiles**


SAFIR




**Steel plate section
node 16**



**Steel shell element with
protection for R60
(60min)**



**Steel shell element
(60min)**



Mechanical actions


$$1.0G_k + \psi_{1,1}Q_{k,1} = 1.0G_k + 0.7Q_{k,1}$$


Permanent loads:

- 77 kN/m³ - dead weight of the steel profiles;
- 0.5 kN/m² - dead weight of the roof;
- 0.3 kN/m² - others permanent loads.

Imposed load:


- 0.5 kN/m² - publicity panels and other suspended objects from the ceiling.






Part C1 with the Fire scenario 2

SAFIR




Truss structure 4

Collapse at 71 min



Truss structure 3

Collapse at 65 min





Truss structure 2

Collapse at 87 min




Part C1 with the Fire scenario 2



SAFIR

Frame of Part C2 with the Fire scenario 2



DIAMOND 2007 for SAFIR

FILE: blocoC2
NODES: 9506
BEAMS: 4244
TRUSSES: 0
SHELLS: 0
SOILS: 0

BEAMS PLOT
DISPLACEMENT PLOT (x 2)


TIME: 13.72134 sec

 Beam Element




SAFIR

Class 4 collumn with non-uniform cross-section




Collapse at 64 min




Without protection - collapse at 14 min
 With protection of R60 (500°C) in the first 9 m height
 - no collapse

Class 4 collumn with non-uniform cross-section

Program Elefir-EN



Localised fire



Without protection - collapse at 14 min


With protection of R60 (500°C) in the first 9 m height
 - no collapse

Class 4 collumn with non-uniform cross-section



Collapse at 64 min

Built up Box cross-section
 of class 4




Note: In a prescriptive approach and without making any calculation, this structure should have been protected for a critical temperature of 350°C and for R60

Parts of the structure / fire scenarios	Result
Part D1 without protection under fire scenario 1	$t_{collapse} = 53 \text{ min}$
Part D1 with protection in the purlins of R30 under fire scenario 1	No collapse
Frame of part D2 under fire scenario 2	$t_{collapse} = 78 \text{ min}$
Truss structure 1 of part D2 under fire scenario 2	$t_{collapse} = 70 \text{ min}$
Truss structure 2 of part D2 under fire scenario 2	$t_{collapse} = 77 \text{ min}$
Beam of part D2 under fire scenario 2	No collapse
Truss structure 1 of part C1 under fire scenario 2	No collapse
Truss structure 2 of part C1 under fire scenario 2	$t_{collapse} = 87 \text{ min}$
Truss structure 3 of part C1 under fire scenario 2	$t_{collapse} = 65 \text{ min}$
Truss structure 4 of part C1 under fire scenario 2	$t_{collapse} = 71 \text{ min}$
Truss structure 5 of part C1 under fire scenario 2	$t_{collapse} = 82 \text{ min}$
Frame of part C2 under fire scenario 2	No collapse
Column with non-uniform cross-section without protection under fire scenario 2	$t_{collapse} = 64 \text{ min}$
Column with non-uniform cross-section without protection under fire scenario 4	$t_{collapse} = 14 \text{ min}$
Column with non-uniform cross-section with protection of R60 in the first 9 m height under fire scenario 4	No collapse



References

- Fire Design of Steel Structures, Jean-Marc Franssen and Paulo Vila Real (2010) – ECCS ed and Ernst & Sohn a Wiley Company ed. www.steelconstruct.com.
- Elefir-EN V1.2.2 (2010), Paulo Vila Real and Jean-Marc Franssen, <http://elefiren.web.ua.pt>.
- The ESDEP (1995), (European Steel Design Education Programme) Society, The Steel Construction Institute.
- DIFISEK + (2008), Dissemination of Fire Safety Engineering Knowledge +.
- Ozone V2.2.6, (2009), <http://www.arcelormittal.com/sections/>.
- SAFIR - A Thermal/Structural Program Modeling Structures under Fire, Jean-Marc Franssen, <http://www.s2v.be/portfolio/safir/>.
- Vila Real, P. M. M.; Lopes, N. “Shopping Centre Dolce Vita em Braga, Portugal”, to Martifer, S.A., LERF - Laboratório de Estruturas e Resistência ao Fogo, Universidade de Aveiro, Junho de 2009.
- Vila Real, P. M. M.; Lopes, N. “Barreiro Reatail Park, Portugal”, to Martifer, S.A., LERF - Laboratório de Estruturas e Resistência ao Fogo, Universidade de Aveiro, Junho de 2009.
- Vila Real, P. M. M.; Lopes, N. “Shopping Centre Oeiras, Portugal”, to Martifer, S.A., LERF - Laboratório de Estruturas e Resistência ao Fogo, Universidade de Aveiro, Junho de 2009.



Thank you for your attention

pvreal@ua.pt